NC/QC/YD/2019-20/W6-PT-CB5A

Date: 23-01-2020

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Providing new borewells and CC Roads, drains development in Nagawara Colony, Behind Pruthvi Theatre in Ward.no.06,Thanisandra.}
Ref.: Material testing/PMC/19-20,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: M/s KRIDL, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{30}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	26-12-19	23-01-20	28	22500	745	33.11	**32.89**
	002	"	"	"	"	740	32.89	
	003	"	"	"	"	735	32.67	

NEWZEN CONSULTANT * BANGALORE *

Page No. 1/1,

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

NC/QC/YD/2019-20/W6-PT-CB6A

Date: 23-01-2020

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Providing new borewells and CC Roads, drains development in Nagawara Colony, Behind Pruthvi Theatre in Ward.no.06,Thanisandra.}
Ref.: Material testing/PMC/19-20,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: M/s KRIDL, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{30}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	26-12-19	23-01-20	28	22500	750	33.33	**33.70**
	002	"	"	"	"	765	34.00	
	003	"	"	"	"	760	33.78	

NEWZEN CONSULTANT * BANGALORE *

Page No. 1/1,

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Enginee
Project Division
Yelahanka Zone
Bangalore

NC/QC/YD/2019-20/W6-PT-CB7A

Date: 25-01-2020

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Providing new borewells and CC Roads, drains development in Nagawara Colony, Behind Pruthvi Theatre in Ward.no.06,Thanisandra.}
Ref.: Material testing/PMC/19-20,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: M/s KRIDL, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{30}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	28-12-19	25-01-20	28	22500	755	33.56	**33.19**
	002	"	"	"	"	745	33.11	
	003	"	"	"	"	740	32.89	

NEWZEN CONSULTANT * BANGALORE *

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Enginee
Project Division
Yelahanka Zone
Bangalore

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/YD/2019-20/W6-PT-CB8A

Date: 25-01-2020

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Providing new borewells and CC Roads, drains development in Nagawara Colony, Behind Pruthvi Theatre in Ward.no.06,Thanisandra.}
Ref.: Material testing/PMC/19-20,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: M/s KRIDL, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{30}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	28-12-19	25-01-20	28	22500	750	33.33	**33.41**
	002	"	"	"	"	740	32.89	
	003	"	"	"	"	765	34.00	

NEWZEN CONSULTANT * BANGALORE *

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

KIRAN. R
M.E, (Civil-Engg)

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187

NC/QC/YD/2019-20/W6-PT-CB9A **Date: 27-01-2020**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Providing new borewells and CC Roads, drains development in Nagawara Colony, Behind Pruthvi Theatre in Ward.no.06,Thanisandra.}
Ref.: Material testing/PMC/19-20,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: M/s KRIDL, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{30}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	30-12-19	27-01-20	28	22500	735	32.67	**33.19**
	002	"	"	"	"	755	33.56	
	003	"	"	"	"	750	33.33	

Page No. 1/1,

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore